

Personal Protective Equipment

Low Medium Voltage

Lines, cabins and cabinet

Code: **GI – DIELECTRIC GLOVES**

Dielectric gloves certified as Personal Protective Equipment in compliance with the International Standard IEC 60903

Insulating gloves in natural latex.



In conformity with	IEC 60903
--------------------	-----------

Type	GI 2.5
Class	00
Length	36 cm / 41 cm
Voltage test	2500 V
Max operating voltage	500 V

Type	GI 5
Class	0
Length	36 cm / 41 cm
Voltage test	5000 V
Max operating voltage	1000 V

Type	GI 10
Class	1
Length	36 cm / 41 cm
Voltage test	10000 V
Max operating voltage	7500 V

Type	GI 20
Class	2
Length	36 cm / 41 cm
Voltage test	20000 V
Max operating voltage	17000 V

Type	GI 30
Class	3
Length	36 cm / 41 cm
Voltage test	30000 V
Max operating voltage	26500 V

Type	GI 40
Class	4
Length	41 cm
Voltage test	40000 V
Max operating voltage	36000 V